

### **Flat Insulated Style Access Door**

Provide and install duct access doors as manufactured by Ward Industries as shown on plans and at each fire damper location. Frame shall be formed of 22 ga. (0.86 mm) galvanized steel complete with notched knock-over tabs for installation. Door shall be formed of 24 ga. (0.70 mm) galvanized steel and be of double skin construction with 1" (25 mm) of insulation fully enclosed within. Neoprene gasket shall be attached to perimeter of frame at point of contact with duct wall and with door for low leakage. Access doors shall be successfully tested to a minimum of 4.5" w.g. (1.2 kPa). Specifier to select fully removable and secured with double camlocks: Ward Model DCM; or hinged on one side with camlock closure: Ward Model DHG.